

**PRASAR BHARTI
BROADCASTING CORPORATION OF INDIA
DOORDARSHAN NEWS: NEW DELHI
SUPPLY ORDER**

TENDER ENQUIRY FORM

File No. DDN/5/ (115)/14(01)/2017-18 G (E)

Dated: 05-05-2017 / 24-05-17

M/s.....O/C.....
.....
.....

Subject: - Rate contract of Hiring of 40 KVA, 62.5 KVA, 120 KVA Silent type DG set along with manpower and required Diesel for VVIP coverages For 01 Year.

Dear Sir,

Please furnish your terms quotation for the supply and delivery in good condition at the destination for the supply of stores mentioned as under:-

SL. NO	DESCRIPTION	QUANTITY	Amount (In Rs.)
	Hiring of 40 KVA, 62.5 KVA, 120 KVA Silent type DG set along with manpower and required Diesel for VVIP coverages for 01 Year The safe and timely deployment of DG set in Delhi / Ghaziabad / Faridabad / Noida / G.Noida / Gurgaon & nearby NCR region on OB spot and after the event de-rigging of DG set is responsibility of entities	01 Job	On Approved rate for on year w.e.f. (01/06/2017) (Technical Specification attached)

1. The quotation in sealed ENVELOPE subscribed with the following details on the quotation should be addressed to be undersigned by name so as to reach him before/upto 1400hrs on 05.06.2017.
2. The quotation must have following indicators.
A) Work for which quotations are enclosed.
B) Reference of letter of inquiry.
C) Due date of opening of quotation.
3. The quotation received without proper sealing may be rejected.
4. Tax / Service tax / may be mentioned clearly.


P. K. MEHROTRA
Assistant Engineer
D. D. News

Page No.2

5. The quotation should specifically and clearly mentioned the following.
 - A) DG set will be used in Delhi and NCR within 50 Kms radius approximately.
 - B) Delivery whenever is required
6. Sales Tax: The Tenders should Quote Sales Tax separately. They should furnish their sales tax number in their quotation
7. Terms of Payment: Full Payment will be made after satisfactory working of DG set at site.
8. Validity: quotation should remain valid for a period of three months from the date of opening.
9. The quotation will be opened in this office at 14.30 Hrs. on the last date i.e....05/06/2017.
10. The DG sets should have silent type.
11. The DG set should have three phase output, 50 Hz (Frequency).
12. The battery of DG set should be fully charged so that Generator could be started in one go.
13. The RPM rating should be 1500 RPM.
14. The radiator should have cooling system.
15. The lubricant oil of Engine should be perfect lubricant.
16. The Generator should have capacity to run at least 12 hours continuously.
17. No payment for the day & 10% Penalty will be imposed in case of failure or any breakdown of DG Set.
18. DG sets along with manpower should reach at the venue within the stipulated date and time as and when order for deployment placed.
19. Silent type DG set should conforms to extant laws / bye laws of various government agency and tribunals.
20. The rate may be quoted in the following slots:-

S.No.	Duration	Rate
1	4 hours	-----
2	1 Day (8 hours) + extra charge on hourly basis	-----
3	2 Days	-----
4	One week	-----

Yours faithfully,


P.K. Mehrotra 24/5/17
Asstt. Engineer
For DDG (E)
P. K. MEHROTRA
Assistant Engineer
D. D. News